



**LUCAS COUNTY BOARD OF DEVELOPMENTAL DISABILITIES
AHU & CU REPLACEMENT AT LARC LANE ADMINISTRATION BUILDING
1154 LARC LANE
TOLEDO, OHIO**

PDG JOB NO. 100262-00001

ADDENDUM NO.2

August 8, 2018

This addendum becomes a part of the plans and specifications for the indicated work and modifies them only to the extent herein set forth.

Attachments: 18064 Larc Lane Transportation AHU Pre Purchase SDR 062718.pdf

DRAWINGS

1. Drawing M101 – HVAC LEGENDS AND SCHEDULES
 - A. Revise Air Cooling Condensing Unit Schedule as follows:
 - i. Revise remark 3 to read as follows: "FURNISH AND INSTALL RAWAL CONTROL VALVE ON ONE CIRCUIT, CAPABLE OF REDUCING UNIT CAPACITY DOWN TO 20%. SIZE AND INSTALL PER MANUFACTURERS WRITTEN INSTRUCTIONS."
 - ii. Remark 4: delete reference to hot gas by-pass line.
2. Drawing M200 – HVAC FLOOR PLANS
 - A. Remove all references to hot gas by-pass line.

*** * END OF ADDENDUM * * ***